

## **TENDER NOTICE**

Employees Old-Age Benefits Institution intends to purchase one Portable Engine Generator **5KVA** (from the available stock) for its Office located at **Shahdara** with the following specifications:

**A. Generator Specification:**

Generator Max Watt	:	6.0 K
Generator Cont. Watt	:	5.5 KW
Generator Output Voltage	:	240 V. Single Phase
Generator Current	:	22.9 Amp. At 240 Volts.
Frequency	:	50 Hz
Winding	:	NEMA Class Insulation
Receptacles	:	4 Standard Outlets

**B. Engine Specification:**

Type of Fuel	:	Tri Fuel (Gasoline, L.P.G. Natural Gas) OR Diesel Fuel
Power	:	11 HP
RPM	:	3000
Starting	:	Recoil & Electric
Fuel Tank	:	4.5 – 5.0 Gallons
Fuel Consumption	:	At full Load
	a.	Gasoline - 1 gal /hr
	b.	L.P.G. - 1.9 gal /hr
	c.	Natural Gas - 16 Cu ft / hr
	d.	Diesel - 1.7 Ltr / Hr

**C. Safety Shutdown** : Low Oil, Circuit Breaker Over Load

**D. Manufacturer** : HONDA (EG-6500CXS)

The interested Firms are invited to submit bids on the prescribed tender documents attached with this notice.

The tender documents duly completed should be submitted alongwith 5% earnest money in the shape of Pay Order / Demand Draft in favour of EOBI which should reach by 11:00 a.m. on **17-08-2012**. These bids will be opened at 11:30 a.m. on the same day in the presence of the bidders or their representatives who may wish to be present.

REGIONAL HEAD  
E.O.B.I. REGIONAL OFFICE SHAHDARA  
PHONE NO.042-37929643-37912731 FAX 042-37941708  
Email Adress:- shahdararegion@eobi.gov.pk

### **GENERAL TERMS AND CONDITIONS:**

1. Supplier shall be responsible for the Installation, Testing and Commissioning complete in all respect at site of EOBI Office.
2. Providing all the material required for the Installation, Testing and Commissioning shall be responsibility of the Supplier. (i.e. Change Over Switch, Board, Wiring and Channel duct of appropriate size etc.
3. Material shall be used of standard quality i.e. Change Over Switch from BRITER ITALY, PVC insulated from Pakistan Cable / Universal Cable / Pioneer Cable, channel duct from Adamjee / Dura duct etc.
4. Supplier can use the existing Distribution Board for the installation of Change Over Switch if the space will be available.
5. EOBI shall arrange the fuel required for Commissioning and Test run.
6. Any modification / additional work required to complete the job apart from the main scope of work shall be the part of the contract.
7. Contractor should have the capability for the Electrical equipment installation work and must have well equipped in house maintenance and support facility / capability.
8. Supplier maintenance team / representative shall visit the site.
9. The rates quoted are lump sum facility with qualified firm inclusive of all the charges involved for the execution of the work as per scope of work, specifications and as directed. No escalation in the rates will be allowed in any case.
10. Before filling the tender, the bidder should (very carefully) read and understand all the terms and conditions of this tender inquiry.
11. Company shall deduct applicable rate of Income Tax from all the Contractor's bills.

### **DELIVERY:**

1. Free delivery at EOBI Office site and no additional transportation charges will be paid.
2. Items tendered should be available in ex-stock, which may be delivered within the given time.

### **INSPECTION:**

1. The equipment shall be inspected at Supplier wear house by the EOBI authorized representative(s) and after approval / clearance by the EOBI, authorized representative(s) equipment will be transported to the respective site at EOBI Office.
2. All the Technical Literature, O & M manuals and Warranty Cards in original should be provided at the time of inspection.

### **WARRANTEE:**

1. Supplier should provide the original manufacturer standard Warrantee / Guarantee of the equipment / spares.
2. Contractor shall provide one year free maintenance services for the supplied equipment with consumable parts.
3. Warrantee period will be started when successful commissioning and testing of the units.

### **PERFORMANCE OF CORRECTIVE WORK:**

1. If EOBI discover at any time within the warranty period, that either the WORK or materials and spare parts supplied by the CONTRACTOR do not conform to the warranty, CONTRACTOR shall within 3 days, after receipt of notice from EOBI, shall promptly perform or arrange for the execution of any corrective work required to replace / repairing the faulty items, materials or fittings supplied by the CONTRACTOR, including all work of removal, disassembly, replacement of material of spare parts, re-assembly and re-installation as may be necessary. Such corrective WORK shall be performed to the satisfaction, of EOBI at no additional cost.
2. If the Vender will fail to attend / rectify the problem, owner will have reserve the right to replace the faulty equipment at Supplier, RISK & COST.

**APPENDIX – A**

(To be filled by Tenderer)

<b>S. No.</b>	<b>DESCRIPTION</b>	<b>QTY.</b>	<b>UNIT RATE</b>	<b>TOTAL AMOUNT</b>
1.	Supply of portable Engine Generator Sets as per following specification: Rating: 6.0 KW Voltage: 240 V , Single Phase Frequency: 50 Hz Type of Fuel: Tri Fuel OR Diesel Manufacturer: Honda / Briggs & Stratton / Winco / PEL / Equivalent.	1 No.		
2.	Installation, Commissioning, and Testing along with Change Over Switch, Wiring and channeling of appropriate rating / size.	1 No.		
	<b>Total Tender Amount</b>			

Amount in words Rupees \_\_\_\_\_

Sales Tax Registration No. \_\_\_\_\_

NTN No. \_\_\_\_\_